

**Southern Ute Indian Tribe
Environmental Programs Division
Air Quality Program
71 Mike Frost Way
Ignacio, Colorado 81137**



**AIR POLLUTION CONTROL
TITLE V PERMIT TO OPERATE**

In accordance with the provisions of Title V of the Clean Air Act (42 U.S.C. 7661-7661f) and Part 1, Article II of the Southern Ute Indian Tribe/State of Colorado Environmental Commission's Reservation Air Code (RAC) and applicable rules and regulations,

**El Paso Natural Gas Company, LLC
Bondad Compressor Station**

is authorized to operate air emission units and to conduct other air pollutant emitting activities in accordance with the conditions listed in this permit.

This source is authorized to operate at the following location:

**Southern Ute Indian Reservation
Section 13, T33N R9W
La Plata County, Colorado**

Terms not otherwise defined in this permit have the meaning assigned to them in the referenced regulations. All terms and conditions of the permit are enforceable by the Tribe and citizens under the Clean Air Act. Citations within this permit are for convenient reference only and have no effect in limiting or extending the applicability of either the RAC provisions that are cited or RAC provisions which may not be cited.



Brenda Jarrell, Air Quality Program Manager
Environmental Programs Division
Southern Ute Indian Tribe

**AIR POLLUTION CONTROL
TITLE V PERMIT TO OPERATE
El Paso Natural Gas Company, LLC
Bondad Compressor Station**

Permit Number: V-SUIT-0028-2014.00	Issue Date:	January 31, 2014
[Replaces EPA-issued Permit No.: V-SU-0028-06.02]	Effective Date:	March 12, 2014
	Expiration Date:	March 12, 2019

The permit number cited above should be referenced in future correspondence regarding this facility.

Permit Issuance History

DATE	TYPE OF ACTION	SECTION NUMBER AND TITLE	DESCRIPTION OF ACTION
June 2001	Initial Part 71 Permit Issued		#V-SU-0028-00.00
October 2007	First Renewal		#V-SU-0028-06.00
January 2008	Administrative Amendment		# V-SU-0028-06.01
October 2009	Administrative Amendment		# V-SU-0028-06.02
January 31, 2014	Initial Part 70 Permit issued		# V-SUIT-0028-2014.00 Replaces EPA-issued permit #V-SU-0028-06.02

Table of Contents

Abbreviations and Acronyms	iii
List of Tables	iv
I. Source Information and Emission Unit Identification	1
I.A. Source Information.....	1
I.B. Source Emission Points.....	2
II. Site Specific Requirements	3
II.A. Requirements for Turbines.....	3
II.A.1. Subpart A – New Source Performance Standards, General Provisions	3
II.A.2. Subpart GG - Standards of Performance for Stationary Gas Turbines.....	3
1. Monitoring Requirements	4
2. Testing Requirements.....	6
3. Recordkeeping Requirements	6
4. Reporting Requirements.....	8
II.B. Requirements for Engines	8
II.B.1. 40 CFR Part 63, Subpart A - National Emission Standards for Hazardous Air Pollutants, General Provisions	8
II.B.2. 40 CFR Part 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants From Reciprocating Internal Combustion Engines.....	8
1. General Requirements	8
2. Operation and Maintenance Requirements	9
3. Monitoring	10
4. Continuous Compliance Requirements.....	10
5. Record Keeping.....	11
III. Facility-Wide Requirements	13
III.A. General Recordkeeping Requirements.....	13
III.B. General Reporting Requirements	13
III.C. Alternative Operating Scenarios for Turbines	15
III.D. Alternative Operating Scenarios for Engines.....	16
III.E. Permit Shield.....	17
IV. Part 70 Administrative Requirements	18
IV.A. Annual Fee Payment	18
IV.B. Compliance Requirements	20
IV.C. Duty to Provide and Supplement Information	21
IV.D. Submissions	22
IV.E. Severability Clause.....	22
IV.F. Permit Actions.....	23
IV.G. Administrative Permit Revision.....	23
IV.H. Minor Permit Revisions	23
IV.I. Significant Permit Revisions.....	24
IV.J. Permit Reopenings, Revocations and Reissuances, and Terminations	25
IV.K. Property Rights	26
IV.L. Inspection and Entry	26
IV.M. Emergency Situations.....	26
IV.N. Permit Transfers	27
IV.O. Off-Permit Changes	27
IV.P. Permit Expiration and Renewal	28
V. Appendix	30

V.A. Inspection Information.....30

Abbreviations and Acronyms

4SLB	Four-Stroke Lean-Burn
4SRB	Four-Stroke Rich-Burn
AFS	Air Facility System database
AQP	Southern Ute Indian Tribe's Air Quality Program
bbf	Barrels
BACT	Best Available Control Technology
CAA	Clean Air Act [42 U.S.C. Section 7401 et seq.]
CAM	Compliance Assurance Monitoring
CEMS	Continuous Emission Monitoring System
CFR	Code of Federal Regulations
CMS	Continuous Monitoring System (includes COMS, CEMS and diluent monitoring)
COMS	Continuous Opacity Monitoring System
CO	Carbon monoxide
CO ₂	Carbon dioxide
dscf	Dry standard cubic foot
dscm	Dry standard cubic meter
EPA	United States Environmental Protection Agency
gal	Gallon
GPM	Gallons per minute
H ₂ S	Hydrogen sulfide
HAP	Hazardous Air Pollutant
hr	Hour
ID	Identification Number
kg	Kilogram
lbs	Pounds
MACT	Maximum Achievable Control Technology
Mg	Megagram
MMBtu	Million British Thermal Units
MMSCFD	Million standard cubic feet per day
mo	Month
NESHAP	National Emission Standards for Hazardous Air Pollutants
NMHC	Non-methane hydrocarbons
NO _x	Nitrogen Oxides
NSPS	New Source Performance Standard
NSR	New Source Review
pH	Negative logarithm of effective hydrogen ion concentration (acidity)
PM	Particulate Matter
PM ₁₀	Particulate matter less than 10 microns in diameter
ppbvd	Parts per billion by volume, dry
ppm	Parts per million
ppmvd	Parts per million by volume, dry
PSD	Prevention of Significant Deterioration
PTE	Potential to Emit
psi	Pounds per square inch
psia	Pounds per square inch absolute
RAC	Southern Ute Indian Tribe/State of Colorado Environmental Commission's Reservation Air Code
RICE	Reciprocating Internal Combustion Engine
RMP	Risk Management Plan
scf	Standard cubic feet
scfm	Standard cubic feet per minute
SI	Spark Ignition
SO ₂	Sulfur Dioxide
SUIT	Southern Ute Indian Tribe
tpy	Ton(s) Per Year
Tribe	Southern Ute Indian Tribe
US EPA	United States Environmental Protection Agency
VOC	Volatile Organic Compounds

List of Tables

Table 1 - Emission Units.....	2
Table 2 - Insignificant Emission Units	2

I. Source Information and Emission Unit Identification

I.A. Source Information

Parent Company Name: El Paso Natural Gas Company, LLC

Plant Name: Bondad Compressor Station

Plant Location: Section 13, T33N R9W
Latitude: N 37.098056
Longitude: W 107.77

State: Colorado

Reservation: Southern Ute Indian Reservation

County: La Plata County

Responsible Official: Division Director

SIC Code: 4922

AFS Plant Identification Number: 08-067-U0012

Other Clean Air Act Permits: This permit replaces the facility's EPA-issued part 71 permit (V-SU-0028-06.02). There are no other CAA permits issued to this facility.

Description of Process:

According to EPNG's permit application, the Bondad Compressor Station is a natural gas compression facility located within the exterior boundaries of the Southern Ute Indian Reservation in southwestern Colorado. The Bondad facility receives gas from a nearby processing plant. The gas enters the facility through inlet scrubbers which knock out small quantities of water and pipeline liquids. The gas is then compressed by three (3) natural gas-fired turbine compressors into the transmission pipeline.

The facility was constructed in December 1981 with the installation of two 2782-hp Solar Centaur natural gas turbine-driven compressors and one natural gas reciprocating engine for auxiliary power generation during purchase power outages. Emissions from the two original turbines were permitted by the Colorado Department of Public Health and Environment. In 1992, a third regenerative-cycle turbine was added (Solar Centaur T4000, 2786-hp). In 1994, the two original turbines were converted from simple cycle to regenerative cycle. In 1997, increases to the NO_x emission limits were incorporated into

the permits for the original two turbines. Pursuant to a Compliance Order on Consent from the CDPHE, all three turbines were replaced with simple-cycle Solar Centaur turbines.

I.B. Source Emission Points

**Table 1 – Emission Units
El Paso Natural Gas Company, LLC, Bondad Compressor Station**

Emission Unit ID	Description	Control Equipment
A-01 A-02	2 – Solar Centaur 50-T6202L simple-cycle, natural gas-fired turbine, 42.72 MMBtu/hr Serial No.: CC80013 (pkg) Installed: 03/19/2004 Serial No.: CC80014 (pkg) Installed: 02/29/2004	None
B-01	1 – Solar Centaur 50-T6202LS simple-cycle, natural gas-fired turbine, 42.72 MMBtu/hr Serial No. CC91308 (pkg) Installed: 04/28/2004	None
A-AUX-01	1 – Waukesha F1197GU natural gas-fired reciprocating internal combustion engine, 235 site-rated hp Serial No. 360792 Installed: 1981	None

**Table 2 – Insignificant Emission Units
El Paso Natural Gas Company, LLC, Bondad Compressor Station**

Emission Unit ID	Description	Size/Rating
	1 – Natural gas-fired building heater	0.25 MMBtu/hr
	1 – Used oil tank	210-bbl
	1 – Lube oil storage tank,	210-bbl
	1 –Used oil tank	167-bbl
	1 – Lube oil day tank,	34-bbl
	Fugitive component VOC emissions	NA
	VOC emissions from unit blowdowns	NA
	VOC emissions from expansion gas	NA
	VOC emissions from station ESD	NA
	Miscellaneous chemicals for maintenance/operation	(<500-gal)
	Pig launcher/receiver	NA

II. Site Specific Requirements

II.A. Requirements for Turbines

II.A.1. Subpart A – New Source Performance Standards, General Provisions

[40 CFR 60.1 – 60.19, RAC 3-102]

- a. 40 CFR Part 60, Subpart A – Standards of Performance for New Stationary Sources, General Provisions: This facility is subject to the requirements of 40 CFR Part 60, Subpart GG. As such, this facility is subject to 40 CFR Part 60, Subpart A. Notwithstanding conditions in this permit, the permittee shall comply with all applicable requirements of 40 CFR Part 60, Subpart A.

[40 CFR 60.1]

II.A.2. Subpart GG - Standards of Performance for Stationary Gas Turbines

[40 CFR 60.330 – 60.335, RAC 3-102]

- a. Applicability

1. This facility is subject to the requirements of 40 CFR Part 60, Subpart GG. Notwithstanding conditions in this permit, the permittee shall comply with all applicable requirements of 40 CFR Part 60, Subpart GG.
2. 40 CFR Part 60, Subpart GG applies to the following emission units:
 - (i) Unit A-01: Solar Centaur 50-T6202L, site-rated 42.72 MMBtu/hr, natural gas fired turbine, Serial Number: CC80013 (pkg)
 - (ii) Unit A-02: Solar Centaur 50-T6202L, site-rated 42.72 MMBtu/hr, natural gas fired turbine, Serial Number: CC80014 (pkg)
 - (iii) Unit B-01: Solar Centaur 50-T6202LS, site-rated 42.72 MMBtu/hr, natural gas fired turbine, Serial Number: CC91308 (pkg)

[40 CFR 60.330]

- b. Emission Standards

1. Units A-01, A-02, and B-01 are subject to the NO_x and SO₂ standards listed in Table 3.

[40 CFR 60.332(a)(2) and 60.333]

**Table 3 - Turbine Emission Standards
El Paso Natural Gas Company, LLC
Bondad Compressor Station**

Pollutant	Emission Standard	Regulatory Reference
NO _x	$\text{STD} = 0.0150(14.4) + F = 180 \text{ ppm}$ Y <p>where: Y= 11.98738 kilojoules per watt hour (manufacturer’s rated heat rate at manufacturer’s rated peak load. The value of Y shall not exceed 14.4 kilojoules per watt hour)</p> <p>and F = 0 (NO_x emission allowance for fuel bound nitrogen) and STD = allowable NO_x emissions (% by volume at 15 % oxygen and on a dry basis)</p>	40 CFR 60.332 (a)(2)
SO ₂	<p>Either:</p> <p>(a) No owner or operator subject to the provisions of this Subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015% by volume at 15% oxygen and on a dry basis;</p> <p>or</p> <p>(b) Fuel sulfur content shall not exceed 0.8% by weight.</p>	<p>40 CFR 60.333(a)</p> <p>40 CFR 60.333(b)</p>

- c. Units A-01, A-02, and B-01 shall be exempted from the NO_x emission standard in this section when being fired with an emergency fuel. For the purpose of this requirement, the term “emergency fuel” means “a fuel fired by a gas turbine only during circumstances, such as natural gas curtailment or breakdown of delivery system, that makes it impossible to fire natural gas in the gas turbine.”

[40 CFR 60.332(k), 40 CFR 60.331(r)]

1. Monitoring Requirements

- a. The permittee may use a CEMS in accordance with 40 CFR 60.334(c) to determine excess emissions.
- b. The permittee shall comply with the requirements of 40 CFR 60.334(h) for monitoring of sulfur content and nitrogen content of the fuel being burned in Units A-01, A-02, and B-01.

1. The permittee shall monitor the total sulfur content of the fuel being fired in Units A-01, A-02, and B-01 using one of the following methods:
 - (i) The permittee shall determine the sulfur content of the fuel using the methods described in §60.335(b)(10); or
 - (ii) If the total sulfur content of the fuel during the most recent performance test was less than 0.4 weight percent, the permittee may determine the sulfur content of the fuel using ASTM D4084-82, 94, D5504-01, D6228-98, or Gas Processors Association Standard 2377-86; or
 - (iii) The permittee shall demonstrate that gaseous fuel burned in Units A-01, A-02, and B-01 meet the definition of natural gas pursuant to §60.331(u) using one of the following sources:
 - (A) The permittee shall demonstrate the gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
 - (B) The permittee shall use representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20.0 grains/100 scf or less.

[40 CFR 60.334(h)(1) and (h)(3)]

[Explanatory Note: Under §60.334(h)(2), monitoring of nitrogen content of the fuel is only required if the permittee claims an allowance for fuel-bound nitrogen. The permittee has not claimed such an allowance.]

- c. The permittee shall measure NO_x emissions from Units A-01, A-02, and B-01 at least once every quarter to show compliance with the requirements of 40 CFR 60.332(a)(2). To meet this requirement, the permittee shall measure the NO_x emissions from the turbine using a portable analyzer and approved monitoring protocol. The portable analyzer specifications and monitoring protocols that have already been approved by the EPA for the emission units in this permit may be used in lieu of new protocols unless the Tribe requires the submittal and approval of new portable analyzer specification and monitoring protocols.
 1. The permittee may conduct a performance test as specified in this permit to satisfy the requirement of quarterly portable analyzer measurements.

2. Monitoring shall begin in the first calendar quarter following permit issuance. At least one calendar month shall separate the quarterly NO_x emissions measurements.
3. If the emission unit is inoperable for 1,500 hours or more in any calendar quarter, the permittee is exempt from conducting NO_x monitoring for the emissions unit for that quarter only.
4. For any one turbine: If the results of 4 consecutive quarterly portable analyzer measurements, starting at the time of permit issuance, are less than 75% of the NO_x emission limit for the turbine, the permittee may reduce the frequency of subsequent monitoring from quarterly to semi-annual. If results from semi-annual portable analyzer measurements are greater than 75% of the emission limit, the monitoring frequency shall change back to quarterly.
5. The permittee shall not perform tuning or make any adjustments to turbine settings, processes or operational parameters immediately prior to the measurements or during measurements. Any such tuning or adjustments may result in a determination that the result is invalid.

[40 CFR 60.334(c) and RAC 2-110(5)(b)]

2. Testing Requirements

- a. Initial performance testing is required for off permit replacement units for turbine Units A-01, A-02, and B-01. The permittee shall comply with the initial performance test requirements of 40 CFR 60.8 for measuring NO_x from replaced Units A-01, A-02, and B-01 within 60 days after achieving the maximum production rate at which the turbines will be operated, but not later than 180 days after initial startup of the turbines.

[Explanatory Note: An off permit replacement unit is any unit which meets the requirements of the Off Permit Changes section of this permit and the provisions at RAC 2-116(2)]

- b. The permittee shall comply with the test methods and procedures of 40 CFR 60.335 when conducting a performance test for NO_x and SO₂ for Units A-01, A-02, and B-01.

[40 CFR 60.8, 40 CFR 60.335, and RAC 2-110(5)(b)]

3. Recordkeeping Requirements

- a. The permittee shall comply with the following recordkeeping requirements:
 1. The permittee shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air

- pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.
2. The permittee shall maintain a file of all measurements, including performance testing measurements, monitoring device calibration checks, and other information required by the Subpart GG conditions of this permit.
- b. The permittee shall comply with the following recordkeeping requirements when firing an emergency fuel:
1. Monitoring of fuel sulfur content shall be recorded daily while firing an emergency fuel as defined in 40 CFR 60.331(r).
 2. Monitoring of fuel nitrogen content shall be recorded daily while firing a fuel other than pipeline-quality natural gas or while firing an emergency fuel as defined in 40 CFR 60.331(r).
- c. The permittee shall keep records of all required monitoring. The records shall include the following:
1. The date, place, and time of sampling or measurements;
 2. The date(s) analyses were performed;
 3. The company or entity that performed the analyses;
 4. The analytical techniques or methods used;
 5. The results of such analyses; and
 6. The operating conditions as existing at the time of sampling or measurement.
- d. The permittee shall keep a record of the number of hours an emissions unit is inoperable and document the reason(s) why the emissions unit was inoperable.
- e. The permittee shall retain records of all required monitoring data and support information, sample analyses, fuel supplier, fuel quality, and fuel make-up pertinent to the custom fuel monitoring schedule for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. These records shall be made available upon request by the Tribe and the EPA. Support information includes all calibration and maintenance records, all original strip-chart

recordings for continuous monitoring instrumentation, and copies of all reports required by this permit.

[RAC 2-110(6), 40 CFR 60.7(b) and 60.7(f)]

4. Reporting Requirements

- a. The permittee shall submit to the Tribe and the EPA a written report of the results of any initial performance test(s) required in this section.

[RAC 2-110(7) and 40 CFR 60.8]

II.B. Requirements for Engines

II.B.1. 40 CFR Part 63, Subpart A - National Emission Standards for Hazardous Air Pollutants, General Provisions [40 CFR 63.1 - 63.16, RAC 4-103]

- a. This facility is subject to the requirements of 40 CFR Part 63, Subpart A as outlined in Table 8 of 40 CFR Part 63, Subpart ZZZZ. Notwithstanding conditions in this permit, the permittee shall comply with all applicable requirements of 40 CFR Part 63, Subpart A.

[40 CFR 63.6665]

II.B.2. 40 CFR Part 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants From Reciprocating Internal Combustion Engines [40 CFR 63.6580 - 63.6675, RAC 4-103]

- a. This facility is subject to the requirements of 40 CFR Part 63, Subpart ZZZZ for existing emergency stationary reciprocating internal combustion engines (RICE) with a site rating of less than 500 brake horsepower located at an area source of hazardous air pollutants (HAPs). Notwithstanding conditions in this permit, the permittee shall comply with all applicable requirements of 40 CFR Part 63, subpart ZZZZ.
- b. 40 CFR part 63, subpart ZZZZ applies to the following engines:

A-AUX-01: 235 site rated bhp, Waukesha F1197GU Emergency Generator, constructed prior to June 12, 2006

1. General Requirements

- a. The permittee must comply with the applicable requirements in Table 2d to this subpart and the operating limitations specified in Table 2b that apply.

[40 CFR 63.6603(a)]

- b. Emission unit A-AUX-01, is an emergency, four-stroke rich-burn (4SRB), stationary, spark ignited (SI), RICE located at an area source of hazardous air pollutants (HAPs), constructed prior to June 12, 2006. According to 40 CFR Part 63, Subpart ZZZZ, there are no emission limitations for this engine category at this time.

[40 CFR 63.6603 and 40 CFR 63.6625(e)]

2. Operation and Maintenance Requirements

- a. The permittee must be in compliance with the emission limitations, operating limitations and other requirements in this subpart at all times.

[40 CFR 63.6605(a)]

- b. At all times, the permittee must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions to the levels required by 40 CFR part 63, Subpart ZZZZ. The general duty to minimize emissions does not require the permittee to make any further efforts to reduce emissions if the required levels have been achieved. Determination of whether such operations and maintenance procedures are being used will be based on information available to the Administrator, which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[40 CFR 63.6605(b)]

- c. For emission unit A-AUX-01, the permittee shall change the oil and filter every 500 hours of operation or annually, whichever comes first. The permittee shall also inspect and replace as necessary all spark plugs every 1,000 of operation or annually, whichever comes first. Finally, the permittee shall inspect and replace as necessary all hoses and belts every 500 hours of operation or annually, whichever comes first.

[Table 2d, item 5 of Subpart ZZZZ]

- d. For engine unit A-AUX-01, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

[40 CFR 63.6625(h)]

- e. For emissions unit A-AUX-01, the permittee shall have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Table 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in

Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[40 CFR 63.6625(j)]

3. Monitoring

- a. For engine unit A-AUX-01, the permittee must install a non-resettable hour meter if one is not already installed.

[40 CFR 63.6625(f)]

4. Continuous Compliance Requirements

- a. The permittee must demonstrate continuous compliance with each emission limitation and operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply according to methods specified in Table 6 to this subpart.
 1. For engine unit A-AUX-01, complying with the work or management practices, the permittee must demonstrate continuous compliance by:
 - (i) Operating and maintaining the stationary RICE according to the manufacturer's emission related operation and maintenance instructions; or
 - (ii) Developing and following your own maintenance plan, which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions

[40 CFR 63.6640(a), 40 CFR 63.6625(e), and Table 6 of Subpart ZZZZ]

- b. The permittee must report each instance in which they did not meet each emission limitation or operating limitation listed in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650.

[40 CFR 63.6640(b)]
- c. The permittee must also report each instance in which the requirements in Table 8 of 40 CFR Part 63, Subpart ZZZZ, are not met.

[40 CFR 63.6640(e)]
- d. For engine unit A-AUX-01, the permittee must follow the operation requirements specified in §63.6640(f)

[40 CFR 63.6640(f)]

5. Record Keeping

- a. The permittee must keep the following records to comply with the emission and operating limitations:
 - 1. A copy of each notification and report that was submitted to comply with 40 CFR Part 63, Subpart ZZZZ, including all documentation supporting any Initial Notification or Notification of Compliance Status that was submitted, according to the requirements of §63.10(b)(2)(xiv);
 - 2. Records of the occurrence and duration of each malfunction of operation (i.e. process equipment) or the air pollution control and monitoring equipment;
 - 3. Records of performance tests and performance evaluations as required in §63.10(b)(2)(viii);
 - 4. Records of all required maintenance performed on the air pollution control and monitoring equipment, if required; and
 - 5. Records of actions taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore

malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

[40 CFR 63.6655(a)]

- b. The permittee must keep the records required in Table 6 of this subpart to show continuous compliance with each applicable emission limitation, operating limitation and work or management practice.

[40 CFR 63.6655(d)]

- c. The permittee must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that the unit and after-treatment control device (if any) was operated and maintained according to the permittee's maintenance plan.

[40 CFR 63.6655(e)]

- d. The permittee must follow the record keeping requirements specified in §63.6655(f)

[40 CFR 63.6655(f)]

- e. Records must be in a form suitable and readily available for expeditious review.

[40 CFR 63.6660(a) and 40 CFR 63.10(b)(1)]

- f. The permittee must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

[40 CFR 63.6660(b) and 40 CFR 63.10(b)(1)]

- g. The permittee must keep each record readily accessible in hard copy or electronic form at the Bondad Compressor Station site, for five (5) years after the date of each occurrence, measurement, maintenance, corrective action, report, or record. Such files may be maintained on microfilm, on a computer, on computer floppy disks, on magnetic tape disks, or on microfiche.

[40 CFR 63.10(b)(1), 40 CFR 63.10(f), and 40 CFR 63.6660(c)]

III. Facility-Wide Requirements

Conditions in this section of the permit apply to all emissions units located at the facility, including any units not specifically listed in Table 1 or Table 2 of the Source Emission Points section of this permit.

[RAC 2-110(1)(d)]

III.A. General Recordkeeping Requirements [RAC 2-110(6)]

The permittee shall comply with the following generally applicable recordkeeping requirements:

1. If the permittee determines that his or her stationary source that emits (or has the potential to emit, without federally recognized controls) one or more hazardous air pollutants is not subject to a relevant standard or other requirement established under 40 CFR part 63, the permittee shall keep a record of the applicability determination on site, at the Bondad Compressor Station for a period of five years after the determination, or until the source changes its operations to become an affected source, whichever comes first. The record of the applicability determination shall include an analysis (or other information) that demonstrates why the permittee believes the source is unaffected (e.g., because the source is an area source).

[40 CFR 63.10(b)(3)]

2. Records shall be kept of off permit changes made, as required by the Off Permit Changes section of this permit.

III.B. General Reporting Requirements

1. The permittee shall submit to the Tribe all reports of any required monitoring under this permit semiannually, by April 1 and October 1 of each year. The report due on April 1 shall cover the July 1 - December 31 reporting period of the previous calendar year. The report due on October 1 shall cover the January 1 - June 30 reporting period of the current calendar year. The initial report shall cover the period from the issuance date of this permit through the end of the relevant semi-annual reporting period. All instances of deviations from permit requirements shall be clearly identified in such reports. All required reports shall be certified by a responsible official consistent with the **Submissions** section of this permit.

[RAC 2-110(7)(a)]

2. "Deviation" means any situation in which an emissions unit fails to meet a permit term or condition. A deviation is not always a violation. A deviation can be determined by observation or through review of data obtained from any testing, monitoring, or recordkeeping established in accordance with RAC 2-110(5) and (6). For a situation lasting more than 24 hours which

constitutes a deviation, each 24 hour period is considered a separate deviation. Included in the meaning of deviation are any of the following:

- (a) A situation where emissions exceed an emission limitation or standard;
- (b) A situation where process or emissions control device parameter values indicate that an emission limitation or standard has not been met; or
- (c) A situation in which observations or data collected demonstrate noncompliance with an emission limitation or standard or any work practice or operating condition required by the permit.
- (d) A situation in which an exceedance or an excursion, as defined in 40 CFR Part 64 occurs.

[RAC 1-103(21)]

3. The permittee shall promptly report to the Tribe deviations from permit requirements, (including emergencies), including the date, time, duration, and the probable cause of such deviations, the quantity and pollutant type of excess emissions resulting from the deviation, and any preventative, mitigation, or corrective actions or measures taken. “Prompt” is defined as follows:
- (a) Where the underlying applicable requirement contains a definition of “prompt” or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern.
 - (b) Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations will be submitted based on the following schedule:
 - (i) For emissions of a hazardous air pollutant or a toxic air pollutant (as identified in the applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made by email, telephone, verbal, or facsimile communication by the close of business the next working day, upon discovery of the occurrence, and in writing within 10 working days from the occurrence;
 - (ii) For emissions of any regulated air pollutant, excluding those listed in RAC § 2-110(7)(b)(i), that continue for more than 2 hours in excess of permit requirements, the report must be made by email, telephone, verbal, or facsimile communication by the close of business the next working day, upon discovery of the occurrence, and in writing within 10 working days from the occurrence;

- (iii) For all other deviations from permit requirements, the report shall be contained in the report submitted with the semi-annual monitoring report.

III.C. Alternative Operating Scenarios for Turbines [RAC 2-110(8)]

1. Replacement of an existing turbine identified in this permit shall be allowed as an off-permit change pursuant to the Off Permit Changes provisions of this permit provided all of the following conditions are met:
 - (a) The turbine replacement is not subject to any requirements under Title IV of the Clean Air Act and is not a modification under Title I of the Clean Air Act;
 - (b) The turbine is of the same make, model, heat input capacity rating, power output capacity rating, and is configured to operate in the same manner as the turbine being replaced.
 - (c) The turbine meets all applicable requirements identified in this permit that apply to the existing turbine being replaced.
 - (d) All applicable requirements that apply to the replacement turbine are already identified in the permit. Replacement of a turbine identified in this permit with a new, modified, or reconstructed turbine must utilize a Minor Permit Revision as specified in RAC 2-111(3) or a Significant Permit Revision as specified in RAC 2-111(4) to incorporate any new applicable requirements. The applicable requirements include, but may not be limited to:
 - (i) Standards of Performance for Stationary Gas Turbines at 40 CFR Part 60, Subpart GG;
 - (ii) Standards of Performance for Stationary Combustion Turbines at 40 CFR Part 60, Subpart KKKK;
 - (iii) National Emission Standard for Hazardous Air Pollutants for Stationary Combustion Turbines at 40 CFR Part 63, Subpart YYYY;
 - (iv) Requirements established in a permit or permits issued pursuant to the Federal Minor New Source Review Program in Indian Country at 40 CFR Part 49;
 - (v) Requirements established in a permit or permits issued pursuant to the Prevention of Significant Deterioration of Air Quality Program at 40 CFR Part 52; or

(vi) Requirements established in any promulgated Federal Implementation Plan that may apply to turbines located on the Southern Ute Indian Reservation.

2. The Permittee shall provide contemporaneous written notice to the Tribe and the Administrator of any replacement of an existing turbine identified in this permit. Such notice shall state when the exchange occurred and shall describe the change and any applicable requirement that would apply as a result of the change.
3. The Permittee shall keep a record of the turbine exchange.

[RAC 2-110(7)(b)]

III.D. Alternative Operating Scenarios for Engines [RAC 2-110(8)]

1. Replacement of an existing engine identified in this permit shall be allowed as an off-permit change pursuant to the Off Permit Changes provisions of this permit provided all of the following conditions are met:
 - (a) The engine replacement is not subject to any requirements under Title IV of the Clean Air Act and is not a modification under Title I of the Clean Air Act;
 - (b) The replacement engine is of the same make, model, horsepower rating, and configured to operate in the same manner as the engine being replaced.
 - (c) The replacement engine meets all applicable requirements identified in this permit that apply to the existing engine being replaced.
 - (d) All applicable requirements that apply to the replacement engine are already identified in the permit. Replacement of an existing engine identified in this permit with a new, modified, or reconstructed engine must utilize a Minor Permit Revision as specified in RAC 2-111(3) or a Significant Permit Revision as specified in RAC 2-111(4) to incorporate any new applicable requirements. The applicable requirements include, but may not be limited to:
 - (i) Standards of Performance for Stationary Spark Ignition Internal Combustion Engines at 40 CFR Part 60, Subpart JJJJ;

- (ii) Standards of Performance for Stationary Compression Ignition Internal Combustion at 40 CFR Part 60, Subpart III;
 - (iii) National Emission Standard for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines at 40 CFR Part 63, Subpart ZZZZ;
 - (iv) Requirements established in a permit or permits issued pursuant to the Federal Minor New Source Review Program in Indian Country at 40 CFR Part 49;
 - (v) Requirements established in a permit or permits issued pursuant to the Prevention of Significant Deterioration of Air Quality Program at 40 CFR Part 52; or
 - (vi) Requirements established in any promulgated Federal Implementation Plan that may apply to engines located on the Southern Ute Indian Reservation.
2. The Permittee shall provide contemporaneous written notice to the Tribe and the Administrator of any replacement of an existing engine identified in this permit. Such notice shall state when the exchange occurred and shall describe the change and any applicable requirement that would apply as a result of the change.
 3. The Permittee shall keep a record of the engine exchange.

III.E. Permit Shield [RAC 2-110(10)(c)]

Nothing in this permit shall alter or affect the following:

1. The provisions of Section 303 of the Clean Air Act, 42 U.S.C. § 7603 concerning emergency powers, including the respective authorities of the Administrator under those sections;
2. The liability of a permittee for any violation of applicable requirements prior to or at the time of permit issuance;
3. The applicable requirements of the acid rain program consistent with section 408(a) of the Act; or
4. The ability of the Administrator respectively to obtain information from a source pursuant to Section 114 of the Clean Air Act, 42 U.S.C. § 7414.

IV. Part 70 Administrative Requirements

IV.A. Annual Fee Payment [RAC 2-110(1)(h) and RAC 2-118]

1. An annual operating permit emission fee shall be paid to the Tribe by the permittee.

[RAC 2-118(2)]
2. The permittee shall pay the annual permit fee each year no later than April 1st for the preceding calendar year, except that the first annual permit fee will cover the period from the issuance date of this permit through December 31 of the same year.

[RAC 2-118(2)]
3. Fee payments shall be remitted in the form of a money order, bank draft, certified check, corporate check, or electronic funds transfer payable to the Southern Ute Indian Tribe and sent or delivered by the United States Postal Service c/o Environmental Programs Division Part 70 Program, P.O. Box 737 MS #84, Ignacio, Colorado 81137; or by common carrier (such as UPS or FedEx) c/o Environmental Programs Division Part 70 Program, 398 Ouray Drive, Ignacio, Colorado 81137.

[RAC 2-118(4)(a)]
4. The permittee shall send an updated fee calculation worksheet submitted annually by the same deadline as required for fee payment to the address listed in the **Submissions** section of this permit.

[RAC 2-118]
5. Basis for calculating annual fee:
 - (a) Subtotal annual fees shall be calculated by multiplying the applicable emission fee set pursuant to RAC § 2-119(1) times the total tons of actual emissions for each fee pollutant. In absence of actual emissions data, calculate the annual fee based on the potential to emit (as defined at RAC 1-103(51)) for each fee pollutant. Emissions of any regulated air pollutant that already are included in the fee calculation under a category of regulated pollutant, such as a federally listed hazardous air pollutant that is already accounted for as a VOC or as PM10, shall be counted only once in determining the source's actual emissions.

[RAC 2-119(2)(a)]
 - (i) "Actual emissions" means the actual rate of emissions in tpy of any fee pollutant (for fee calculation) emitted from a title V source over the preceding calendar year

or any other period determined by the Tribe to be more representative of normal operation and consistent with the fee schedule adopted by the Tribe and approved by the Administrator. Actual emissions shall be calculated using each emissions units actual operating hours, production rates, in-place control equipment, and types of materials processed, stored, or combusted during the preceding calendar year or other period used for this calculation.

[RAC 1-103(2)]

- (ii) Actual emissions shall be computed using compliance methods required by the permit.

[RAC 2-118(1)(b)]

- (iii) If actual emissions cannot be determined using the compliance methods in the permit, the permittee shall use other federally recognized procedures.

[RAC 2-118(1)(b)]

- (b) The total annual fee submitted shall be the greater of the applicable minimum fee or the sum of subtotal annual fees for all fee pollutants emitted from the source.

[RAC 2-119(2)(b)]

[Explanatory note: The applicable emission fee amount and applicable minimum fee (if necessary) are revised each calendar year to account for inflation, and they are available from AQP prior to the start of each calendar year.]

- (c) The permittee shall exclude the following emissions from the calculation of fees:

- (i) The amount of actual emissions of any one fee pollutant that the source emits in excess of 4,000 tons per year
- (ii) Any emissions that come from insignificant activities not required in a permit application pursuant to RAC § 2-106(4).

[RAC 1-103(2)(c)]

- 6. Annual fee calculation worksheets shall be certified as to truth, accuracy, and completeness by a responsible official.

[RAC 2-105 and RAC 2-118(2)(c)]

- 7. Failure of the permittee to pay fees by the due date shall subject the permittee to assessment of penalties and interest in accordance with RAC § 2-118(6).

[RAC 2-118(6)]

8. When notified by the Tribe of underpayment of fees, the permittee shall remit full payment within 30 days of receipt of an invoice from the Tribe.

[RAC 2-119(3)(b)]

9. A permittee who thinks a Tribe assessed fee is in error and who wishes to challenge such fee shall provide a written explanation of the alleged error to the Tribe along with full payment of the assessed fee.

[RAC 2-119(3)(c)]

IV.B. Compliance Requirements

1. Compliance with the Permit

- (a) The permittee must comply with all conditions of this part 70 permit. Any permit noncompliance with federally enforceable or Commission-only permit conditions constitutes a violation of the RAC and Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or for denial of a permit renewal application.

[RAC 2-110(3)(a)]

- (b) It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

[RAC 2-110(3)(b)]

- (c) All terms and conditions of this permit which are required under the Clean Air Act or under any of its applicable requirements, including any provisions designed to limit a source's potential to emit, are enforceable by the Administrator and citizens under the Clean Air Act, except terms and conditions the permit specifically designates as not being federally enforceable under the Clean Air Act that are not required under the Clean Air Act or under any of its applicable requirements. Terms and conditions so designated are not subject to the requirements of RAC §§ 2-108, 2-111, 2-112, other than those contained in this paragraph.

[RAC 2-110(3)(f)]

- (d) This permit, or the filing or approval of a compliance plan, does not relieve any person from civil or criminal liability for failure to comply with the provisions of the RAC and the Clean Air Act, applicable regulations thereunder, and any other applicable law or regulation.

[RAC 2-110(3)(g)]

- (e) For the purpose of submitting compliance certifications in accordance with the Compliance Certifications condition below of this permit, or establishing whether or not a person has violated or is in violation of any requirement of this permit, nothing shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.

[Section 113(a) and 113(e)(1) of the Act, 40 CFR §§ 51.212, 52.12, 52.33, 60.11(g), and 61.12]

2. Compliance Certifications

The permittee shall submit to the Tribe and the Administrator an annual certification of compliance which shall certify the source's compliance status with all permit terms and conditions and all applicable requirements relevant to the source, including those related to emission limitations, standards, or work practices. The compliance certification shall be certified as to truth, accuracy, and completeness by a responsible official consistent with RAC § 2-110(9)(a). The certification of compliance shall be submitted annually by April 1st and shall cover the preceding calendar year in which the certification of compliance is due, except that the first annual certification of compliance will cover the period from the issuance date of this permit through December 31st of the same year.

[RAC 2-110(9)(c)]

3. Compliance Schedule

- (a) For applicable requirements with which the source is in compliance, the source will continue to comply with such requirements.

[RAC 2-106(4)(1)(ii)]

- (b) For applicable requirements that will become effective during the permit term, the source shall meet such requirements on a timely basis.

[RAC 2-106(4)(1)(iii)]

IV.C. Duty to Provide and Supplement Information [RAC 2-110(7)(e), 2-106(5), and 2-124]

- 1. The permittee shall furnish to the Tribe, within the period specified by the Tribe, any information that the Tribe request in writing to determine whether cause exists for reopening and revising, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Tribe copies of records that are required to be kept by the permit, including information claimed to be confidential. Information claimed to be

confidential must be accompanied by a claim of confidentiality according to the provisions of RAC 2-124.

[RAC 2-110(7)(e) and RAC 2-124]

2. The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application or in a supplemental submittal, shall promptly submit such supplementary facts or corrected information. In addition, a permittee shall provide additional information as necessary to address any requirements that become applicable after the date a complete application is filed, but prior to release of a draft permit.

[RAC 2-106(5)]

IV.D. Submissions [RAC 2-105]

1. Any application, form, report, compliance certification, or other document submitted by the permittee under this permit shall contain a certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

[Explanatory Note: The Tribe has developed a reporting form “CTAC” for certifying truth, accuracy and completeness of part 70 submissions. The form may be found on the AQP’s website (<http://www.southernute-nsn.gov/environmental-programs/air-quality>).

2. Except where otherwise noted, any documents required to be submitted under this permit, including reports, test data, monitoring data, notifications, compliance certifications, fee calculation worksheets, and applications for renewals and permit modifications shall be submitted:

by United States Postal Service:

Part 70 Program
Environmental Programs Division
Air Quality Program
P.O. Box 737 MS #84
Ignacio, Colorado 81137

or by Common Carrier:

Part 70 Program
Environmental Programs Division
Air Quality Program
398 Ouray Drive
Ignacio, CO 81137

IV.E. Severability Clause [RAC 1-106 and RAC 2-110(1)(f)]

The provisions of this permit are severable, and in the event of any challenge to any portion of this permit, or if any provision is held invalid, the remaining permit conditions shall remain valid and in force.

IV.F. Permit Actions [RAC 2-110(3)]

1. This permit may be modified, reopened and revised, revoked and reissued, or terminated for cause.

[RAC 2-110(3)(c)]

2. The filing by the permittee of a request for a permit revision, reissuance, or termination, or of a notification of planned changes or anticipated noncompliance shall not stay any permit condition.

[RAC 2-110(3)(d)]

IV.G. Administrative Permit Revision [RAC 2-111(2)]

1. The permittee may submit an application for an administrative permit revision as defined in RAC § 1-103.

[RAC 2-111(2)(a)]

2. The permittee may implement an administrative permit revision immediately upon submittal of the request for the administrative revision.

[RAC 2-111(2)(c)]

[Note to permittee: If the provisions allowing for an administrative permit revision do not apply, please contact the Air Quality Program for a determination of similarity prior to submitting your request for an administrative permit revision.]

IV.H. Minor Permit Revisions [RAC 2-111(3)]

1. The permittee may submit an application for a minor permit revision as defined in RAC § 1-103.
2. An application requesting the use of minor permit revision procedures shall meet the requirements of RAC § 2-106(4) and shall include the following:
 - (a) A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
 - (b) If changes are requested to the permit language, the permittee's suggested draft permit changes;
 - (c) Certification by a responsible official, consistent with RAC § 2-105, that the proposed revision meets the criteria for use of minor permit revision procedures and a request that such procedures be used; and

- (d) Completed forms for the Tribe to use to notify the Administrator and affected programs as required under RAC § 2-108
- (e) If the requested permit revision would affect existing compliance plans or schedules, related progress reports, or certification of compliance requirements, and an outline of such effects.

[RAC 2-111(3)(a)]

- 3. The permittee shall not submit multiple minor permit revision applications that may conceal a larger revision that would not constitute a minor permit revision.

[RAC 2-111(3)(b)]

- 4. The permittee may make the change proposed in its minor permit revision application immediately after it files such application, provided, however, for sources that have previously utilized this provision during the term of the permit and, on two or more occasions have failed to file a complete application, may thereafter make the change only after the application is deemed complete. After the permittee makes the change and until the Tribe takes any of the actions specified in the following subsection, the permittee must comply with both the applicable requirements governing the change and the proposed permit terms and conditions. During this period, the permittee need not comply with the existing permit terms and conditions it seeks to modify. If the permittee fails to comply with its proposed permit terms and conditions during this period, however, the existing permit terms and conditions it seeks to modify may be enforced against it.

[RAC 2-111(3)(e)]

- 5. The permit shield under RAC § 2-110(10) does not extend to minor permit revisions.

[RAC 2-110(10)(d)]

IV.I. Significant Permit Revisions [RAC 2-111(4)]

- 1. The permittee must request the use of significant permit revision procedures as defined in RAC § 1-103.
- 2. Significant permit revisions shall meet all requirements of the RAC for permit issuance and renewal, including those for applications, review by the Administrator and affected programs, and public participation.

[RAC 2-111(4), 2-109, and 2-106(3)]

IV.J. Permit Reopenings, Revocations and Reissuances, and Terminations [RAC 2-112]

1. The permit may be reopened and revised for any of the reasons listed in paragraphs (a) through (d) below. Alternatively, the permit may be revoked and reissued for the reasons listed in paragraphs (c) and (d) below:
 - (a) Additional requirements under the Clean Air Act become applicable to a major source with a remaining permit term of 3 or more years, provided that the Tribe shall revise such permits to incorporate such additional requirements no later than 18 months after promulgation of such requirements, and no such reopening is required if the effective date of the requirement is later than the permit expiration date unless the original permit or any of its terms or conditions have been extended past the permit expiration date pursuant to RAC § 2-104(2)(b)(iii);
 - (b) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit;
 - (c) The Tribe or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the terms or conditions of the permit;
or
 - (d) The Tribe or the Administrator determines that the permit must be revised or revoked and reissued to assure compliance with applicable requirements.

2. The permit may be terminated for any of the reasons in (a) through (g) below:
 - (a) The permittee fails to meet the requirements of an approved compliance plan;
 - (b) The permittee has been in significant or repetitious noncompliance with the operating permit terms or conditions;
 - (c) The permittee has exhibited a history of willful disregard for environmental laws of any tribal or state authority, or of the United States;
 - (d) The permittee has knowingly misrepresented a material fact in any application, record, report, plan, or other document filed or required to be maintained under the permit;
 - (e) The permittee falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained under the permit;

- (f) The permittee fails to pay fees required under RAC §§ 2-118 and 2-119; or
- (g) The Administrator has found that cause exists to terminate the permit.

IV.K. Property Rights [RAC 2-110(3)(e)]

This permit does not convey any property rights of any sort, or any exclusive privilege.

IV.L. Inspection and Entry [RAC 2-110(9)(b)]

Upon presentation of credentials and other documents as may be required by law, the permittee shall allow authorized representatives of the Tribe or other authorized representative to perform the following:

1. Enter upon the permittee's premises where a source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
4. As authorized by the Clean Air Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

IV.M. Emergency Situations [RAC 2-117]

1. The permittee may seek to establish that noncompliance with a technology-based emission limitation under this permit was due to an emergency as defined in RAC § 1-103. To do so, the permittee shall demonstrate the affirmative defense of emergency through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (a) An emergency occurred and that the permittee can identify the cause(s) of the emergency;
 - (b) The permitted facility was at the time being properly operated;
 - (c) During the period of the emergency the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards, or other requirements in this permit; and
 - (d) The permittee reported the emergency to the Tribe in compliance with RAC § 2-110(7).

[RAC 2-117(1)]

2. In any enforcement preceding the permittee attempting to establish the occurrence of an emergency has the burden of proof.

[RAC 2-117(2)]

3. This emergency situation provision is in addition to any emergency or upset provision contained in any applicable requirement.

[RAC 2-117(3)]

IV.N. Permit Transfers [RAC 2-113]

This permit shall not be transferable, by operation of law or otherwise, from one location to another or from one source to another, except that a permit may be transferred from one location to another in the case of a portable source that has notified the Tribe in advance of the transfer, pursuant to the RAC. A permit for a source may be transferred from one person to another if the Tribe finds that the transferee is capable of operating the source in compliance with the permit. This transfer must be accomplished through an administrative permit revision in accordance with the Administrative Permit Revisions section of this permit.

IV.O. Off-Permit Changes [RAC 2-116(2)]

1. The permittee is allowed to make, without a permit revision, certain changes that are not addressed or prohibited by this permit provided that the following requirements are met:
 - (a) Each such change meets all applicable requirements and shall not violate any existing permit term or condition;
 - (b) Such changes are not subject to any requirements under title IV of the Clean Air Act and are not modifications under title I of the Clean Air Act;
 - (c) Such changes are not subject to permit revision procedures under RAC § 2-111; and
 - (d) The permittee provides contemporaneous written notice to the Tribe and the Administrator of each such change, except for changes that qualify as insignificant activities. Such notice shall state when the change occurred and shall describe the change, any resulting emissions change, pollutants emitted, and any applicable requirement that would apply as a result of the change.

[RAC 2-116(2)(a)]

2. The permit shield does not apply to changes made under this provision.

[RAC 2-110(10)(d)]

3. The permittee shall keep a record describing changes made at the source that result in emissions of any regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes.

[RAC 2-116(2)(b)]

4. The notice shall be kept on site, at Bondad Compressor Station, and made available to the Tribe on request, in accordance with the general recordkeeping provision of this permit.

5. Submittal of the written notice required above shall not constitute a waiver, exemption, or shield from applicability of any applicable standard or PSD permitting requirements under 40 CFR 52.21 that would be triggered by the replacement of any one {emission unit type}, or by replacement of multiple {emission unit type}.

IV.P. Permit Expiration and Renewal [RAC §§ 2-104(3), 2-106(2)(b), 2-107(7)(a), 2-107(7)(b), 2-110(1)(a), and 2-106(3)]

1. This permit shall expire five years from the effective date of this permit.

[RAC 2-110(1)(a)]

2. Expiration of this permit terminates the permittee's right to operate unless a timely and complete permit renewal application has been submitted at least 6 months but not more than 18 months prior to the date of expiration of this permit.

[RAC 2-107(7)(b)]

3. If the permittee submits a timely and complete permit application for renewal, consistent with RAC § 2-106 but the Tribe has failed to issue or disapprove a renewal permit before the end of the permit term, then the permit shall not expire and all its terms and conditions shall remain in effect until the renewal permit has been issued or disapproved.

[RAC 2-104(2)(b)]

4. The ability to operate under this permit shall cease if (1) the Tribe takes final action to issue the permittee a renewal permit or deny the permittee a permit or (2) the permittee fails to submit by the deadline specified in writing by the Tribe any additional information identified as being needed to process the application.

[RAC 2-104(3)]

5. Renewal of this permit is subject to the same procedures, including those for public participation and affected program and EPA review, as those that apply to initial permit issuance.

[RAC 2-107(7)(a)]

6. The application for renewal shall include the current permit number, description of permit revisions and off permit changes that occurred during the permit term, any applicable requirements that were promulgated and not incorporated into the permit during the permit term, and other information required by the application form.

[RAC 2-106(4)(e)(ix)]

V. Appendix

V.A. Inspection Information

1. Driving Directions to the facility:

From the city of Durango, Colorado, go south on Highway 550 approximately 18 miles to La Plata County Road 318. Go east on county road 318 for approximately 7.5 miles. Take a left turn from County Road 318 to Bondad Compressor Station.

2. Global Positioning System (GPS):

Latitude: N 37.098056

Longitude: W 107.77

3. Safety Considerations:

All visitors to the Bondad Compressor Station are required to wear a hard hat, safety glasses, safety toe footwear, fire-retardant clothing, and hearing protection.