



22 40 00 PLUMBING FIXTURES

Revision January 2026

1. Fixtures

- a. Southern Ute Tribe prefers American Standard fixtures with Chicago Faucet trim.
- b. All Restroom Water Closets and Urinals shall have Automatic Flush Valves
 - i. Automatic flush valves: AA-Battery back units preferred. Automatic flush valves to have integrated battery recharging feature such as light harvesting or mechanical charging turbine.
 - ii. Water Closets are to be single flush or dual flush not exceeding flush volume of 1.28 gallons per flush.
 - a. Architect will request direction from SUIT Project Manager.
 - b. Automatic flush operation is acceptable, as long as the 1.28 gallons per flush is maintained.
 - iii. Urinals are to be 1 pint per flush, or 0.5 gallons per flush.
 1. Waterless urinals are not permitted.
- c. All Restroom Sinks shall have 2 Handle Chicago Faucet or equivalent
- d. Water fountains with integrated bottle-filling stations should be considered.
- e. Accepted Manufactures: Sloan, Zurn for Automatic Flush Valves.

END OF SECTION 22 40 00